



United States Department of State

Washington, D.C. 20520

DEC 14 2009

CPI Daylighting, Inc.
28662 N. Ballard Drive
Lake Forest, Illinois 60045

Attention: Mr. Moshe Konstantin

Dear Mr. Konstantin:

Based upon your request, a Department of State (DOS) technical representative witnessed the forced entry test of the CPI Daylighting FE-4pc Curtain Wall on 13 November 2009 and has since evaluated the H. P. White Laboratory Test Report HPWLI 11201-02A.

The model number FE-4pc Curtain Wall has been determined to meet the DOS certification criteria for 5-minute forced entry. Under the provisions of SD-STD-01.01, Revision G (Amended), *Certification Standard, Forced Entry and Ballistic Resistance of Structural Systems*, The FE-4PC Curtain Wall has been certified with a DOS code of 2114 and the DOS model number of GPX-05N-CPI-01. Please refer to the DOS model number in all correspondence with the Department of State.

The GPX-05N-CPI-01 will be placed on the DOS list of certified equipment which is available for use by architects and planners. Your product still has to compete with other bidding manufacturers who are certified with the same classification. We cannot guarantee that your product will be chosen by the architects that design the facilities.

Thank you for your interest and endeavors in protecting our personnel and facilities overseas.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Peter G. Gibbons".

Peter G. Gibbons
Division Chief
Physical Security Division
Bureau of Diplomatic Security